

## Lead in Drinking Water – Public and Nonpublic Schools

### **IMPORTANT FOLLOW-UP NOTICE: MEASURES TAKEN** **Summit Park Elementary School**

#### **ELEVATED LEAD WATER SAMPLE RESULT(S)**

All Maryland public and nonpublic schools are required to sample all drinking water sources for the presence of lead pursuant to the Code of Maryland Regulations. On March 2, 2019, 42 water samples were collected from Summit Park Elementary School. Of these water samples, seven (7) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Summit Park Elementary School were as follows:

181 parts per billion (ppb) Bubblers, Room 16

#### **ACTION LEVEL (AL)**

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

#### **FOLLOW-UP RESULTS**

On February 8, 2020, samples were re-tested from the locations listed above. Sample results are still above the AL for the Bubblers, Room 16.

#### **ACTIONS TAKEN WITH DATES**

These fixtures were replaced prior to resampling. They will be remediated by being removed from service.

#### **ADDITIONAL INFORMATION**

1. For additional information, please contact David Glassman, Supervisor, Environmental Services at 443.809.6310 or [dglassman2@bcps.org](mailto:dglassman2@bcps.org).
2. For additional information about reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead).
3. If you are concerned about exposure, contact your healthcare provider. If you do not have a healthcare provider, please contact the Baltimore County Department of Health at 410.887.3725.