

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT FOLLOW-UP NOTICE: MEASURES TAKEN

Timber Grove Elementary School

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water sources for the presence of lead pursuant to the Code of Maryland Regulations. On January 12, 2019, 41 water samples were collected from Timber Grove Elementary School. Of these water samples, nine (9) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Timber Grove Elementary School were as follows:

28.3 parts per billion (ppb) Tap, Room 102, Handsink
21.0 parts per billion (ppb) Tap, Room 104, Handsink
61.9 parts per billion (ppb) Bubbler, Room 105
52.7 parts per billion (ppb) Tap, Room 105, Handsink
95.2 parts per billion (ppb) Tap, Room K2, Handsink
38.8 parts per billion (ppb) Tap, Room 205, Handsink
22.8 parts per billion (ppb) Tap, Room 206, Handsink
23.9 parts per billion (ppb) Tap, Room 209, Handsink
386 parts per billion (ppb) Tap, Room 210, Handsink

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

FOLLOW-UP RESULTS

On February 15, 2020, samples were re-tested from the locations listed above. Samples are now below the AL for all fixtures except the following:

Tap, Room 104, Handsink
Tap, Room 105, Handsink
Tap, Room 209, Handsink

ACTIONS TAKEN WITH DATES

These fixtures were replaced prior to resampling. The fixtures that are below the action level were returned to normal service on March 3, 2020 after sampling results were received. Fixtures that are above the action level were turned off and will be remediated and resampled.

ADDITIONAL INFORMATION

1. For additional information, please contact David Glassman, Supervisor, Environmental Services at 443.809.6310 or dglassman2@bcps.org.
2. For additional information about reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure, contact your healthcare provider. If you do not have a healthcare provider, please contact the Baltimore County Department of Health at 410.887.3725.